



# KOMO<sup>®</sup>

## Technical approval-with product certificate

### K101516-3



Issued 2025-08-01 Replaces K101516/02  
Valid until Indefinite Dated 2021-05-01  
Page 1 of 3

GOLD-FIX system 3400

## General Fittings S.p.A.

### STATEMENT BY KIWA

This technical approval-with-product certificate on the basis of BRL 5606 Plastics piping systems of PE-X intended for heating installations: radiator connections issued on 25 October 2016 by Kiwa, in accordance with the Kiwa Regulation for Certification.

The quality system and the product characteristics belonging to the GOLD-FIX system 3400 are checked periodically and the performance of the GOLD-FIX system 3400 in the application as floor heating is assessed. The basic principles for the assessment are checked periodically.

Based on this Kiwa declares that :

- legitimate confidence exists that the by the holder of the technical approval- with-product certificate delivered GOLD-FIX system 3400 comply with :
  - the technical specifications as laid down in this technical approval-with-product certificate;
  - the product requirements as laid down in this technical approval-with-product certificate , provided that they have been marked the GOLD-FIX system 3400 with the KOMO<sup>®</sup>-mark in the manner as indicated in this technical approval-with-product certificate;
- the GOLD-FIX system 3400 provides the performances as described in this KOMO technical approval-with-product certificate, provided that:
  - the application conditions and technical specifications as described in this KOMO approval-with-product certificate are met;
  - the manufacturing takes place according to the processing methods as laid down in this technical approval-with-product certificate.

Within the framework of this KOMO technical approval-with-product certificate there is no inspections with regard to the production of other parts of the GOLD-FIX system 3400 or the processing of the GOLD-FIX system 3400.

Ron Scheepers  
Kiwa

*This technical approval-with-product certificate is also included on the KOMO foundation websites: [www.komo.nl](http://www.komo.nl) and [www.komo-online.nl](http://www.komo-online.nl).*

*Users of this technical approval-with-product certificate are advised to check whether it is still valid. For this purpose consult the website of Kiwa: [www.kiwa.com](http://www.kiwa.com).*

Kiwa Nederland B.V.  
Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
NL.Kiwa.info@Kiwa.com  
[www.kiwa.com](http://www.kiwa.com)

Certificate holder  
General Fittings S.p.A.  
Via Gogli 73/75  
25064 GUSSAGO (BS)  
Italië  
Tel. 390 30 3739017  
Fax 390 30 3739021  
info@generalfittings.it  
[www.generalfittings.it](http://www.generalfittings.it)



Assessed is:  
• Quality system  
• Product  
• Performance in the application  
Periodic control

## GOLD-FIX system 3400

## TECHNICAL SPECIFICATION

**Subject**

GOLD-FIX system 3400

**Product characteristics**

The product complies to BRL 5606 Plastics piping systems of PE-X intended for heating installations: radiator connections.

The system consists of:

- 3-layer pipes (PE-Xa/EVOH) manufactured by Pipe Water Solutions S.L.U. (certificate K101517);
- Axial press fittings manufactured by General Fittings S.R.L (certificate K97443);
- Protection pipes manufactured by Redi (certificate K24836).

**Specification**

The dimensions of the pipe in the table below are part of this certificate.

Nominal outside diameter (mm)	Wall thickness (mm)
16	2,2
20	2,8
25	3,5
32	4,4

Colour: Inside natural/outside silver

Remarks: to be used with RE press profile

**Marking**

The products shall be marked with the KOMO® mark.

**Pipes**

The minimum required marking on the pipes shall be:

- KOMO (or KOMO® word mark) + class 4 or 5/ 6 bar;
- material identification: PE-Xa;
- the build up of the pipe; PE-Xa//EVOH;
- certificate number of accompanying technical approval-with-product certificate of the piping system;
- the manufacturer's name, trade name, system name or logo;
- nominal outside diameter in mm;
- nominal wall thickness of the pipe in mm;
- production code.

The realization of the marks is as follows: clearly, durable and indelible at intervals of not more than 2 meters.

**Fittings**

The minimum required marking on the fittings shall be:

- KOMO (if not possible KOMO only on the smallest packaging);
- the manufacturer's name, trade name or logo;
- nominal outside diameter of the corresponding pipe;
- production code.

Location of the marks: on every fitting.

The realization of the marks is as follows: clearly, durable and indelible.

The minimum required marking on the smallest packaging unit of the fitting shall be:

- KOMO (or KOMO® word mark);
- certificate number of the accompanying technical approval-with-product certificate of the piping system, according the marking of the belonging pipe;
- the manufacturer's name, trade name, system name or logo;
- material identification if the fitting body is made of plastics;



## GOLD-FIX system 3400

---

- nominal outside diameter and nominal wall thickness of the corresponding pipe in mm.

Location of the marks: on every package.

The realization of the marks is as follows: clearly, durable and indelible on every packaging.

### Protection pipes

The minimum required marking on the protection pipes shall be:

- KOMO (KOMO<sup>®</sup> word mark);
- the manufacturer's name, trade name, certificate number of the protection pipe or the certificate number of the belonging technical approval (system) certificate.

The realization of the marks is as follows: clearly and indelible at intervals of not more than 2,5 m.

### Logistics

Production and assembly of the system is laid down in the annex of the certification agreement.

### PROCESSING

The supplier shall provide installation instructions, approved by Kiwa. A reference to these instructions shall be made at or near the packaging. The instructions are published in the Dutch language and contains at least specific information with regard to storage, transport, processing temperature and construction of the joints.

So-called "combination boilers" are often applied in individual house heating systems. In such boilers, no double separation between drinking water and heating medium exists. A leak in the single separation may result in the heating medium coming into contact with drinking water. Because of this it is important that in case additives are added to the heating medium a Kiwa product certificate for these additives has been issued.

The heat emission to the floor is dependent on the thickness of the finishing coat and the mutual distance between the pipes. The preconditions have to be clearly described in the instructions.

### PERFORMANCES

1. The system is oxygen tight.
2. All joints are leak tight and possess sufficient clamp force to resist external influences.

### PERFORMANCES OF THE PRODUCTS

The medium pipes and fittings are designed for heating installations: radiator connections and floor heating systems with a lifetime of 50 years at an operating temperature profile according to class 4/ 5 of NEN-ISO 10508 and an allowable working pressure of maximum 6 bar. The corrugated protection pipes have to protect the medium pipes for radiator connections in case the medium pipes are embedded.

### RECOMMENDATIONS FOR THE CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

Examine at delivery of the products mentioned under "processing" that they comply to the mentioned specifications.

if you should reject a delivery on the basis of the above, please contact:

- General Fittings S.p.A.

and, if necessary:

- Kiwa Nederland B.V.

For the proper storage, transport and processing follow the instructions given under "processing".

Take notice of the application conditions given under "Performances in application".

