



Certificate number: 2410775 (1)

Issued 30/10/2024

Expires 30/10/2029

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

General Fittings S.p.A.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
General Fittings S.p.A
Via Golgi
73/75 – 25064
Gussago (BS)
Italy



KUKreg4

Product Certificate

Appendix to Certificate number: 2410775

The following products belong to this certificate

<p>PRODUCT DESCRIPTION Brass stop valves with chromium plated brass bodies, EPDM 'O' rings and seals and various dome operating members. ATS3 – Without Production Surveillance.</p>
<p>MODEL(S) 140049C0404Z0A ½" BSP (M) x ½" BSP (M) 140049C040400A ½" BSP (M) x ½" BSP (M) 140074C040400A ½" BSP (M) x ½" BSP (M) 140074C040300A ½" BSP (M) x 3/8" BSP (M)</p>
<p>SIZE: See models.</p>
<p>SCOPE: Manufacturer recommended maximum working pressure 5.0 Bar & maximum operating temperature 85°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C.</p>
<p>MARKING General Fittings logo etched on body.</p>
<p>MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.</p>
<p>BACKFLOW PROTECTION NOTES N/A.</p>
<p>ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.</p>

Extra Notes